

## CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 262/14**

Test specification: **EN 1568-3 : 2008, EN 1568-4 : 2008**

Test report no.: **2012-F-2078/Sth 144**

Requested by: **Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG  
Liebigstraße 5, 22113 Hamburg**

Manufacturer: **Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG  
Liebigstraße 5, 22113 Hamburg**

Name of the fire  
extinguishing medium: **MOUSSOL-APS LV 1/1 F-15 #6101**

Grade of foam concentrate: **Aqueous film-forming alcohol resistant foam concentrate (AFFF-AR)  
according to annex A EN 1568**

Test fire performance: **Extinguishing performance and burn-back resistance:**  
**Low expansion foam according to EN 1568-3 (1%)**  
with potable water / with simulated sea water: **I B / I B**  
**Low expansion foam according to EN 1568-4 (1%) (alcohol resistant foam concentrate)**  
with potable water / with simulated sea water: **I C / I C (acetone)**  
with potable water / with simulated sea water: **I C / I C (isopropanol)**

Freezing point: **- 24,5 °C**

Notes: **–**


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

12<sup>th</sup> January 2015



Grad. Eng. Jürgen Dittrich  
Laboratory Manager

